

Kershaw County RFP # 16-600-08

Design-Build Emergency Medical Services (EMS) Stations

September 27, 2016

Addendum III

1. No zoning changes are required for the construction of the EMS station on either of the properties shown on the RFP. The County has the right to install the EMS station at any site that is determined to be necessary.
2. The fire sprinkler system for the living area of the EMS station may be constructed from PVC piping. The fire sprinkled system in the ambulance bays shall be constructed from steel piping.
3. The ambulance bay and the living quarters do not have to be contained in the same building. The living space and the ambulance bay may be separated by a walkway.
4. The ambulance bay must contain a rollup door for the ambulances.
5. City water is available at the Elgin and Bethune properties.
6. Multiple bids will be accepted from a single proposer. Each bid shall be submitted in separate envelopes.